RE: BOOSTER PUMP STATION

EMI PROJECT No. 22-005

CITY OF HOSCHTON, GEORGIA

FROM: ENGINEERING MANAGEMENT, INC.

303 SWANSON DRIVE

LAWRENCEVILLE, GA 30046

Russ Brink, P.E. 770-962-1387

TO: PROSPECTIVE BIDDERS

This Addendum forms a part of the Contract Documents and Drawings and modifies the original bidding documents dated March 2023.

The following items of the Contract Documents are modified as part of this Addendum:

SPECIFICATIONS:

> <u>Section 16621 Standby Generator and Transfer Switch</u> has been added to the bid documents (see attached) and the Table of Contents will be updated accordingly. A copy is attached.

CONSTRUCTION DRAWINGS:

- > Sheet E1- Pump Station (see attached revised sheet E1)
 - o The generator shall be supplied and installed by the contractor and note 9 has been added to the One Line Diagram Notes.
 - o Prewired VFD's are now shown on the pumps.

END OF ADDENDUM NO. 1