

**ADDENDUM NO. ONE (1)**  
**TOWN OF BRASELTON, GEORGIA**  
**INDUSTRIAL PARK LIFT STATION REPLACEMENT**  
**ISSUED OCTOBER 17, 2024**

---

RE: INDUSTRIAL PARK LIFT STATION REPLACEMENT  
EMI PROJECT No. 22-029  
Town of Braselton, Georgia

FROM: ENGINEERING MANAGEMENT, INC.  
303 SWANSON DRIVE  
LAWRENCEVILLE, GA 30043  
Zack C. Bryan, P.E.  
770-962-1387

TO: PROSPECTIVE BIDDERS

---

**This Addendum forms a part of the Contract Documents and Drawings, and modifies the original bidding documents dated September 2024.**

---

The following items of the Contract Documents are modified as part of this Addendum:

**Specifications:**

➤ Section 00840, Administrative & Procedural Items and Forms

1. The Forms and Documents listed in 2.01 were not completely provided.

A complete copy of the updated Section 00840, Administrative & Procedural Items and Forms is attached and is to replace the previous Section 00840, Administrative & Procedural Items and Forms in its entirety.

**Plans:**

➤ Sheet LS-2 & LS-3

1. The wetwell wall thickness was not clearly called out. A dimension of 8-inches has been added.
2. The Odor Control units manufacturer and model were not specified. This information has been added.

A copy of the updated Sheets LS-2 and LS-3 are attached and are to replace the previous Sheets LS-2 and LS-3 in its entirety.

END OF ADDENDUM NO. 1